

CITY OF LOS ANGELES
CALIFORNIA

DEPARTMENT OF
BUILDING AND SAFETY
201 NORTH FIGUEROA STREET
LOS ANGELES, CA 90012

BOARD OF
BUILDING AND SAFETY
COMMISSIONERS

VAN AMBATIELOS
PRESIDENT

JAVIER NUNEZ
VICE PRESIDENT

JOSELYN GEAGA-ROSENTHAL
GEORGE HOVAGUIMIAN
ELVIN W. MOON



ERIC GARCETTI
MAYOR

OSAMA YOUNAN, P.E.
GENERAL MANAGER
SUPERINTENDENT OF BUILDING

JOHN WEIGHT
EXECUTIVE OFFICER

Sto Corp.
6175 Riverside Dr SW
Atlanta, GA 30331

RESEARCH REPORT: RR 24708
(CSI #09220)

Expires: May 1, 2023

Issued Date: July 6, 2021

Code: 2020 LABC

Attention: Kevin Schroeder
(678) 928-3341

GENERAL APPROVAL – Technical Modification and Renewal - Sto Coatings on Interior or Exterior Noncombustible Substrates.

DETAILS

Sto coating systems of various textures and colors consist of acrylic and water based co-polymer binder bases, synthetic resin plasters, portland cement, sand, stone chips and other special fillers. The coatings are applied by toweling, rolling, brushing, or spraying to a uniform thickness depending on the specific product being applied to the substrate.

The coatings listed below have a flame spread index of 25 or less and a maximum smoke-developed rating of 70 when tested in accordance with ASTM E-84.

Brand Names	Testing Agency	Report Date
Sto Base Coats and Adhesives		
Sto Primer/Adhesive-B	Southwest Research Institute	6/22/2007
Sto BTS-Plus Adhesive Base	U.S. Testing Co., Inc.	2/4/2000
Sto RFP	U.S. Testing Co., Inc.	9/25/1990
Sto BTS-Xtra	QAI Laboratories, Inc.	3/10/2010
Sto Armat Classic Plus	Intertek-ATI	9/4/2020
Sto Air and Moisture Barriers		
Sto Gold Coat	Intertek Testing Services	12/18/2018
Sto Gold Fill	U.S. Testing Co., Inc.	9/1/2000
StoGuard VaporSeal	Southwest Research Institute	1/30/2014

RR 24708
Page 1 of 3

Sto Corporation

RE: Sto Coatings on Interior or Exterior Noncombustible Substrates.

Sto AirSeal	Intertek Testing Services	7/20/2016
Sto Emerald Coat	Southwest Research Institute	6/22/2007
Sto Primers		
Sto Prime	U.S. Testing Co., Inc.	3/22/1989
Sto Hot Prime	Omega Point Laboratories	7/28/2004
Sto Finishes		
Sto Essence D.P.R.	Southwest Research Institute	6/22/2007
Stolit	U.S. Testing Co., Inc.	9/25/1990
Stolit Lotusan	QAI Laboratories, Inc.	2/28/2009
Stolit X	Intertek Testing Services	10/28/2016
StoSilco Lit	Commercial Testing Co., Inc.	1/17/1991
Stolit HDP Finish	Intertek	03/11/2021
Sto Ventec Carrier board	Qai Laboratories	10/29/2019
Sto Veneer Wood	Intertek	04/29/2021
Stucco Finishes		
Sto Powerflex	Commercial Testing Co., Inc.	1/17/1991
Sto Powerflex Silco	Southwest Research Institute	11/25/1992
Coatings		
StoColor Lastic	Intertek Testing Services	3/15/2019
StoColor Silcolastic	Intertek Testing Services	3/15/2019
StoColor Acryl Plus	Intertek Testing Services	6/28/2018
StoColor Dryonic	Intertek Testing Services	6/28/2018
StoColor Lotusan	Intertek Testing Services	8/12/2019
Specialty Finishes		
Stolit Milano	Southwest Research Institute	1/30/2014
StoColor Metallic	Intertek Testing Services	4/22/2020

Sto coating systems for application over interior or exterior noncombustible substrates are approved with the following conditions:

1. Application of the coatings shall be in accordance with the manufacturer's technical bulletins. Copies of the bulletins shall be provided at each jobsite.
2. Where weather protection or waterproofing is required by Section 1402 and 1805, respectively, of the 2020 Los Angeles City Building Code or by the Department for

Sto Corporation

RE: Sto Coatings on Interior or Exterior Noncombustible Substrates.

special site conditions, such weather protection or waterproofing shall be provided by other approved means.

3. Where noncombustible construction is required by the 2020 Los Angeles City Building Code, the applied thickness of the coating shall not exceed $\frac{1}{8}$ -inch.

DISCUSSION

The technical modification is to add Stolit HDP Finish, Sto Ventec Carrier board and Sto Veneer Wood to be part of the approval.

The report is in compliance with the 2020 Los Angeles City Building Code.

The approval is based on surface burning characteristics tests conducted in accordance with ASTM E-84.

This approval is only for those coatings which have been tested. Other coatings by the same manufacturer are not approved.

Addressee to whom this Research Report is issued is responsible for providing copies of it, complete with any attachments indicated, to architects, engineers and builders using items approved herein in design or construction which must be approved by Department of Building and Safety Engineers and Inspectors.

This general approval of an equivalent alternate to the Code is only valid where an engineer and/or inspector of this Department has determined that all conditions of this approval have been met in the project in which it is to be used.



QUAN NGHIEM, Chief
Engineering Research Section
201 N. Figueroa St., Room 880
Los Angeles, CA 90012
Phone- 213-482-0409
Email- quan.nghiem@lacity.org

QN
RR24708
R07/06/2021
TLB2100093 & TLB2100094
801 and 803